



NOTE:

1. PIPES MADE FROM UNLIKE MATERIALS SHALL BE COUPLED TOGETHER USING AN APPROPRIATELY SIZED COATED, STEEL-BARRELED, COMPRESSION TYPE COUPLING AS MANUFACTURED BY SMITH-BLAIR COUPLING, OR AN APPROVED EQUAL TRANSITION COUPLING SUITABLE FOR WASTEWATER APPLICATIONS.
2. MISSION TYPE COUPLINGS MAY BE APPROVED FOR 6" (150 mm) DIAMETER OR 8" (200 mm) DIAMETER PIPE BY PCWMD UNDER SPECIAL CONDITIONS.
3. WHERE THERE IS A 1" (25 mm) DIFFERENTIAL IN INTERNAL DIAMETERS OF THE 2 DIFFERENT PIPE TYPES A SPECIAL CONNECTION APPROVED BY PCWMD SHALL BE USED TO ELIMINATE THE DIFFERENTIAL AT THE INVERT.
4. SEE NOTE #11 OF DETAIL WWM 106 FOR SPECIAL COATING AND WRAP REQUIREMENTS.

ISSUED:		STANDARD DETAIL COUPLING FOR UNLIKE PIPE MATERIALS		DETAIL NO.
8/92				WWM 103
REVISED:				SHEET 1 OF 1
7/02				