



NOTES:

THE MINIMUM THICKNESS OF ANY BARREL OR ADJUSTMENT RING SECTION SHALL BE 1/2 THE INSIDE DIAMETER.

THE MINIMUM WALL THICKNESS OF ANY CONE SECTION SHALL BE 1/2 THE LARGEST INSIDE DIAMETER. THE WALL THICKNESS SHALL NOT BE LESS THAN 5% OR 3/16 INCH (5 MILLIMETERS), WHICHEVER IS GREATER OF THE WALL THICKNESS NOTED ON THE PLANS.

VARIATIONS IN THE INSTALLED LENGTH OF TWO OPPOSITE SIDES OF THE MANHOLE BARREL OR CONE SECTION SHALL NOT EXCEED 5/8 INCH (16 MILLIMETERS).

A DEFICIENCY IN THE LENGTH OF A BARREL OR CONE SECTION SHALL NOT BE MORE THAN 1/4 INCH PER FOOT (20 mm per meter) OF THE LENGTH OF THE SECTION WITH A MAXIMUM DEFICIENCY IN THE TOTAL LENGTH OF THE SECTION BEING 1/2 INCH (13 MILLIMETERS).

ISSUED:
8/92
DELETED
1/02



STANDARD DETAIL
 PRECAST CONCRETE
 MANHOLE (4' DIA)



DETAIL NO.
WWM 205
SHEET 1 OF 1