



**NOTE:**

ALL SANITARY SEWER MANHOLES REQUIRING FRAME AND COVER ELEVATION ADJUSTMENTS SHALL HAVE THE CHANNEL(S) COVERED WITH PLYWOOD OR SIMILAR MATERIAL (APPROVED BY PCWMD) DURING THE MODIFICATIONS TO PREVENT DEBRIS FROM ENTERING THE SEWER LINES. ONCE THE MODIFICATIONS ARE COMPLETE, OR AS DIRECTED BY THE ENGINEER, THE PROTECTIVE COVER SHALL BE REMOVED. FOR 24 INCH (610 mm) MANHOLE OPENINGS TO A 5 FOOT (1.52 m) MANHOLE, THE PLYWOOD WILL REQUIRE 2 HINGED JOINTS AT THE THIRD POINTS OF THE CIRCULAR COVER.

ISSUED:		STANDARD DETAIL		DETAIL NO.
8/92		MANHOLE CHANNEL		WWM 307
REVISED:		COVER		SHEET 1 OF 1
7/02				